# പതിനാലാം കേരള നിയമസഭ അഞ്ചാം സമ്മേളനം

നക്ഷത്രചിഹ്നമിടാത്ത ചോദ്യം നമ്പർ<u>: 5174</u>

<u>22/5/2017 -</u>ലെ മറുപടി

#### മണ്ഡലത്തിലെ കുടിവെള്ള ക്ഷാമം പരിഹരിയ്ക്കവാൻ പ്പഞ്ഞാർ പദ്ധതി

&

## ചോദ്ദ്യം

ശ്രീ. പി.സി.ജോർജ്ജ്

### മറുപടി

മാതൃ ടി.തോമസ് (ജലവിഭവ വകപ്പുമത്തി)

- കടിവെള്ള ക്ഷാമം നേരിടുന്ന പൂഞ്ഞാർ (എ) നിയോജകമണ്ഡലത്തിലെ ഈരാറ്റുപേട്ട മുനിസിപ്പാലിറ്റി, പൂഞ്ഞാർ, തീക്കോയി ഗ്രാമപഞ്ചായത്തുകളെ ഉൾപ്പെടുത്തി സപ്ലൈ സ്മീം ഈരാറ്റപേട്ട വാട്ടർ അടിയന്തരമായി നടപ്പാക്കണമെന്ന 31/01/2017-ലെ എം.എൽ.എ-യുടെ നിവേദനത്തിന്മേൽ ബഹ മത്ത്രി 14/02/2017-ൽ അതോറിറ്റി വാട്ടർ 1724/M(WR)എം.ഡി-യ്ക്കോടുത്ത VIP/2017 നമ്പർ കത്ത് പ്രകാരം നാളി തുവരെ എന്ത് നടപടികൾ സ്വീകരിച്ച എന്ന് വെളിപ്പെടുത്തുമോ;
- കാര്യത്തിൽ പ്രസ്തത കേരള (ബി) അതോറിറ്റി എം.ഡി-യുടെ റിപ്പോർട്ട്/ നടപടികളുടെ പകർപ്പ് ലഭ്യമാക്കുമോ;
- പ്രസ്തത പ്രദേശത്തെ കുടിവെള്ളക്ഷാമം (സി) പരിഹരിയ്ക്കവാൻ അടിയന്തരമായി പദ്ധതി നടപ്പാക്കുമോ; എങ്കിൽ ഇതിലേയ്ക്കായി എന്തൊക്കെ നടപടികൾ സ്വീകരിയ്ക്കമെന്ന് വിശദമാക്കുമോ?

- പദ്ധതി നടപ്പാക്കുന്നത് സംബന്ധിച്ച (എ), സാധ്യതാ പഠന റിപ്പോർട്ട് കേരള വാട്ടർ (ബി) അതോറിറ്റി **പൂർത്തിയാക്കിയിട്ടു**ണ്ട്. ഇതിൻപ്രകാരം അതോറിറ്റി വാട്ടർ (സി)
  - പ്രോജകു് ഡിവിഷനിലേയും കോട്ടയം പി.പി.ഡി-യിലേയും **ഉദ്യോ**ഗസ്ഥർ ഈരാറ്റപേട്ട 12/4/2017-ൽ **ത്തിൽ നിലവിൽ ഉള്ള വാട്ടർ അ**തോറിറ്റി കടിവെള്ള പദ്ധതിയുടെ **സോ**തസ്സ് **പര്യാപ്തമല്ല എന്ന് കണ്ടെത്തുകയു**ണ്ടായി. ആയതിനാൽ മലങ്കര **സ്രോതസ്സായിട്ടുള്ള രാമപുരം പദ്ധതിയി**ത് മുനിസിപ്പാലിറ്റി ഈരാറ്റപേട്ട **ഉൾപ്പെടുത്തി പരിഷ്ക്കരിക്കുകയും** പൈപ്പ് ലൈൻ ഈരാറ്റപേട്ടയിലേക്ക് ദീർഘിപ്പി **ക്കുകയും വേണം. (പരിശോധനാ** റിപ്പോർ ട്ടിന്റെ പകർപ്പ് അനബന്ധമായി ചേർത്തി രിക്കുന്നു). സർവേ **നടപടി**കൾ **പൂർത്തിയായ ശേഷം മാത്രമേ പൂ**ഞ്ഞാർ. തീക്കോയി പഞ്ചായത്തുകളടെ

പരിഗണിക്കുവാൻ കഴിയുകയുള്ള.

**സെക്ഷൻ ഓഫീ**സർ

# Inspection Report of Water Supply - Sources in Poonjar Legislative Assembly Constituency

-The inspection was carried out on 12-04-2017 along with Sri. P.C. George, MLA, Smt. A Vijayam, Superintending Engineer, PPD, M. Luqman, Deputy Chief Engineer, PPD, Sri. Anil Raj. Assistant Executive Engineer, Kottayam Project, Sri. Mathew Chacko, Assistant Engineer, Kottayam Project in the presence of local body members at the respective places.

A meeting was convened by the MLA with Erumely Panchayath members at PWD Rest House Erumeli. MLA insisted that the gaps in distribution main in Erumeli town and balance distribution lines to be completed urgently. Sri. Anil Raj, AEE & Sri. Mathew Chacko, AE, Project have explained non-availability of road cutting sanction is the reason for not completing the distribution main and non availability of fund for balance distribution line road cutting. The MLA promised to do necessary follow up at PWD for the sanction. It is also told that the power supply to the scheme will be obtained soon.

The team has visited Erumeli Water Treatment Plant and then to Koruthodu Panchayath as requested by the MLA. The Panchayath with population of about 21000 also desires for a KWA Scheme. A source on Azhutha River was shown by the Panchayath members. A check dam need be constructed. The upstream portion of the weir comes in Periyar Tiger reserve. It is better to provide an independent water supply project for this Panchayath considering the geographical location.

## Mundakayam Panchayath

The Manimala River Source at Mundakayam is almost dry when the team visited. There is also possibility of contamination of the source by town wastes discharged through drains.

Mundakayam has a town area with lot of commercial institutions and most of it habitations face acute scarcity of water. Hence it is better to bring water from Erumeli Scheme by enhancing the existing treatment plant capacity and laying a Clear water main. The distance from Mundakayam town to Erumeli Water Treatment Plant is about 14 Km.

Source at Erumeli is told to be adequate due to weir down stream of intake for Erumeli at Edathikavu.

#### **Erattupetta Municipality**

Most part of the Municipality face acute water scarcity during summer. This is Municipal town with lot of shops and commercial establishments.

Meenachil River is the Source for the Water Supply Scheme. Kerala Water Authority has only a pumping arrangement without any treatment plant. A few smaller intake wells by Janakeeya Samithees are also existing. About 50m upstream of KWA's intake point a weir constructed by Jalanidhi for Thalapalam Panchayath is existing. During the discussion with the Municipal Chairman it was told that a diversion weir by KSeb near Wagamon. Both the weirs reduced the discharge in the river considerably to Erattupetta's intake point.

Thus, the source at Erattupetta is inadequate for any water supply scheme to this Municipality. So, the possibility of drawing treated water from Ramapuram Scheme at Neeloor which is located at about 23 Km has to be considered. The Ramapuram Scheme has to be appropriately revised.

M. Luqman

Deputy Chief Engineer (PPD)

Kerala Water Authority, Thiruvananthapuram.

ONBiles Broomed