

15 -ാം കേരള നിയമസഭ

16 -ബം സമ്മേളനം

നികുതി പിന്നം ഇല്ലാത്ത പ്രോഡ്യൂസ് നം. 1118

02-02-2026 - തു മുട്ടപ്പട്ടിക്ക്

ഹരിപ്പാട് കട്ടിവെള്ള പദ്ധതി

പ്രോഡ്യൂസ്	ഉത്തരം
ശ്രീ രമേഷ് ചെന്നിത്തല	ശ്രീ രോഷീ അഗസ്റ്റിൻ (ജലവിഭവ വകുപ്പ് മന്ത്രി)
(എ) ഹരിപ്പാട് കട്ടിവെള്ള പദ്ധതിയുടെ നിർവ്വഹണ പുരോഗതി അറിയിക്കാമോ;	(എ) ഹരിപ്പാട് മുനിസിപ്പാലിറ്റിയും സമീപ പഞ്ചായത്തുകളും ഉൾപ്പെടുത്തി ജർജീവൻ മിഷൻ (JJM) പദ്ധതിയുടെ ഭാഗമായി നടപ്പിലാക്കുന്ന CWSS to Haripad and Adjoining Panchayats പദ്ധതിയിൽ വിവിധ പഞ്ചായത്തുകളിലായി വിതരണ ശ്രദ്ധാലൂദ നിർമ്മാണം, പെപ്പ് ലൈൻ സ്ഥാപിക്കൽ, ടാപ്പ് കണക്ഷൻകൾ (FHTC) നൽകൽ തുടങ്ങിയ പ്രവൃത്തികൾ വിവിധ ജലടങ്ങളിലായി പുരോഗതി വരുത്താണ്. ഫോസ്-1 രൂപീ ഭാഗമായി 50 MLD WTP, പള്ളിപ്പാട് OHSR, മൂല്യമുറ്റിക്കടവിലെ ഇൻഡോക്ക് വെൽ തുടങ്ങിയ പ്രധാന പ്രവൃത്തികൾ ഇതിനകം പുർത്തീകരിച്ചിട്ടുണ്ട്. പ്രവൃത്തികളുടെ പുരോഗതി സംബന്ധിച്ചും ഇന്നീ നടത്തേണ്ട പ്രവർത്തനങ്ങളെക്കുറിച്ചും വിശദാംശം അനുബന്ധമായി ചേർത്തിരിക്കുന്നു.
(ബി) ഹരിപ്പാട് കട്ടിവെള്ള പദ്ധതിയുടെ പുർത്തീകരണത്തിനായി ഇന്നീ എത്രത്തോം പ്രവർത്തനങ്ങളാണ് നടത്തേണ്ടതെന്ന് അറിയിക്കാമോ;	(ബി) അനുബന്ധമായി ചേർക്കുന്നു.
(സി) നിയതമായ സമയക്രമം നിശ്ചയിച്ചുകൊണ്ട് ഹരിപ്പാട് കട്ടിവെള്ള പദ്ധതിയുടെ ശേഷിക്കുന്ന നിർവ്വഹണ പ്രവർത്തനങ്ങൾ എത്രയും വേഗം പുർത്തീകരിച്ചു തുക്കന്നപുഴ, ആറാട്ടപുഴ എന്നിവ അടക്കം മണ്ണല്ലത്തിലെ വിവിധ പ്രദേശങ്ങൾ നേരിട്ടുന്ന കട്ടിവെള്ളക്ഷാമം പരിഹരിക്കുന്നതിനായി നടപടികൾ സീകർച്ചു വരുന്നു. ദർശാന്തർ ലഭിക്കാത്ത പ്രവൃത്തികൾക്ക് പുതക്കിയ എസ്റ്റിമേറ്റുകൾ തയ്യാറാക്കി അംഗീകാരം നേടുന്ന നടപടികൾ പുരോഗതി വരികയാണ്;	(സി) ഹരിപ്പാട് കട്ടിവെള്ള പദ്ധതിയുടെ ശേഷിക്കുന്ന നിർവ്വഹണ പ്രവർത്തനങ്ങൾ എത്രയും വേഗം പുർത്തീകരിച്ചു തുക്കന്നപുഴ, ആറാട്ടപുഴ എന്നിവ അടക്കം മണ്ണല്ലത്തിലെ വിവിധ പ്രദേശങ്ങൾ നേരിട്ടുന്ന കട്ടിവെള്ളക്ഷാമം പരിഹരിക്കുന്നതിനായി നടപടികൾ സീകർച്ചു വരുന്നു. ദർശാന്തർ ലഭിക്കാത്ത പ്രവൃത്തികൾക്ക് പുതക്കിയ എസ്റ്റിമേറ്റുകൾ തയ്യാറാക്കി അംഗീകാരം നേടുന്ന നടപടികൾ പുരോഗതി വരികയാണ്.
(ഡി) സംസ്ഥാനത്ത് നടപ്പിലാക്കി വരുന്ന വിവിധ ജർജീവൻ മിഷൻ പദ്ധതികളുടെ നിർവ്വഹണ കാലാവധി 2028 വരെ നീട്ടിയതായി പ്രവൃത്തിച്ചിട്ടുണ്ട്. എന്നാൽ നിർവ്വഹണ കാലാവധി	(ഡി) 2025-26 ലെ കേരള ബഡ്ജറ്റിൽ ജർജീവൻ മിഷൻ പദ്ധതിയുടെ കാലാവധി 2028 വരെ നീട്ടിയതായി പ്രവൃത്തിച്ചിട്ടുണ്ട്. എന്നാൽ നിർവ്വഹണ കാലാവധി

	സർക്കാർഡിൽ ഉത്തരവ് ലഭ്യമായിട്ടുണ്ടോ; ഇല്ലെങ്കിൽ കാലതാമസത്തിൽ കാരണം അറിയിക്കാമോ;	തീർഖലിപ്പിച്ചെക്കാണ്ടുള്ള കേന്ദ്ര സർക്കാർഡിൽ ഉത്തരവ് ലഭ്യമായിട്ടില്ല.
(ഇ)	ഇത്തരവിൽ മിഷൻ നിർവ്വഹണ കാലാവധി 2028 വരെ നീട്ടിയതായി ബബ്ധജൂഡിൽ പ്രവ്യാപിച്ച നീട്ടിയിരിക്കുന്ന സാഹചര്യത്തിൽ, Letter of Acceptance (LoA) നൽകുന്നതിനുള്ള കാലാവധി നീട്ടിണമന്നാവശ്യപ്പെട്ടുകൊണ്ട് നാഷണൽ ജൂഡിജീവൻ മിഷൻ 29.10.2024, 03.07.2025 തീയതികളിൽ കത്ത് നൽകിയിട്ടുണ്ട്. കൂടാതെ പ്രസ്തുത വിഷയം നാഷണൽ ജൂഡിജീവൻ മിഷൻ അവലോകന യോഗങ്ങളിൽ നിരതരം ഉന്നയിച്ചിട്ടുള്ളതുമാണ്.	(ഇ)

സെക്രഡൽ ഓഫീസർ

Sl No.	Name of work	Present Status
1	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Arattupuzha Panchayath	26% completed
2	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Chingoli Panchayath	39% completed
3	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Cheruthana Panchayath	35% completed
4	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Cheppad Panchayath	58% completed
5	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Devikulangara Panchayath	65% completed
6	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Karuvatta Panchayath	51% completed
7	Haripadu and adjoining Panchayaths-Construction of 6LL OHSR at Karuvatta Panchayath	Agreement executed. Work yet to start.
8	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Karthikappally Panchayath	86% completed
9	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Kandalloor Panchayath	36% completed
10	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Kumarapuram Panchayath	56% completed
11	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Pallippad Panchayath	56% completed
12	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Pathiyoor Panchayath	60% completed

13	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Thrikunnapuzha Panchayath	50% completed
14	Jal Jeevan Mission - CWSS to Haripad Municipality and adjoining panchayaths - Supplying and laying of distribution network and providing Functional Household Tap Connections (FHTC) for Muthukulam Panchayath	51% completed
15	Supplying and laying of 800 mm Raw water Pumping Main using Spirally Welded MS pipe 10 mm thick from intake well at Mannar to WTP Pallippad	Ongoing
16	Laying transmission main to newly proposed OHSR at Thrikkudam & Construction of 7 LL OHSR at Thrikkudam	Ongoing
17	Electromechanical works- Pumps, Transformer, VCB, Main Control Panel, RMU etc. in WTP at Pallippad, and Sump at Muthukulam	Agreement executed. To be started

#### Packages yet to arrange.

Sl No.	Zone	Grama Panchayat	Components	Tender status
1	Zone -I	Pallippad, Cheppad Pathiyoor	6LL OHSR at Cheppad, 7LL OHSR at Pathiyoor, Transmission Main from WTP Pallippadu to Cheppad and Pathiyoor OHSR.	No bidders participated in tender. Hence, the retender procedures are being arranged by recasting the estimate based on SoR 2021
2	Zone -II	Cheruthana Kumarapuram	5LL OHSR at Cheruthana, 6LL OHSR at Kumarapuram Transmission Main from Pump No.3,4 & 5 up to Haripad Block Office Junction up to Kumarapuram OHSR	No bidders participated in tender. Hence, the retender procedures are being arranged by recasting the estimate based on SoR 2021
3	Zone -III	Thrikkunnappuzha Karthikappally Chingoli	7.5 5LL OHSR at Thrikkunnappuzha, 6LL OHSR at Karthikappally, 5LL OHSR at Chingoli Pumping main from Haripad Block Office Junction to Karuvatta OHSR From Haripad Block Office Junction to Thrikkunnappuzha, Karthikappally, Chingoli tanks up to St.Thomas Church then to Chingoli Tanks.	No bidders participated in tender. Hence, the retender procedures are being arranged by recasting the estimate based on SoR 2021
4	Zone -IV	Muthukulam	6 LL OHSR and 10 LL Sump at Muthukulam Pumping main from St.Thomas Church then to Muthukulam Sump	No bidders participated in tender. Hence, the retender procedures are being arranged by recasting the estimate based on SoR 2021

			From St.Thomas Church to VettathukadavuJn to MallikattukadavuJn to Pattoli Market Jn (Not Crossing Canal) From MallikkattukadavuJn to Existing Mallikkattukadavu OHSR,	
5	Zone -V	Arattupuzha Kandalloor Devikulangara	9 LL OHSR at Arattupuzha, 6 LL OHSR at Kandalloor 6 LL OHSR at Devikulangara. Pumping main from Pattoli Market Jn To Arattupuzha OHSR From Pattoli Market Jn to Perumpally bridge east Jn To existing Perumpally Sump. From Perumpally east Jn to Kandalloor OHSR and Devikulangara OHSR	No bidders participated in tender. Hence, the retender procedures are being arranged by recasting the estimate based on SoR 2021