

**15 -ാം കേരള നിയമസഭ**

**16 -ാം സമ്മേളനം**

**നക്ഷത്ര ചിഹ്നം ഇല്ലാത്ത ചോദ്യം നം. 2598**

**23-02-2026 - ൽ മറുപടിയ്ക്ക്**

**വെനിയൂർ സബ് സ്റ്റേഷൻ**

ചോദ്യം		ഉത്തരം	
<b>ശ്രീ. കെ. പി. എ. മജീദ്</b>		<b>ശ്രീ. കെ. കൃഷ്ണൻകുട്ടി (വൈദ്യുതി വകുപ്പ് മന്ത്രി)</b>	
(എ)	തിരൂരങ്ങാടി നിയോജക മണ്ഡലത്തിലെ വെനിയൂർ സബ്സ്റ്റേഷൻ പൂർണ്ണമായി പ്രവർത്തനസജ്ജമായിട്ടുണ്ടോയെന്ന് വിശദമാക്കാമോ;	(എ)	തിരൂരങ്ങാടി മണ്ഡലത്തിൽ വെനിയൂരിൽ ഒരു 33 kV സബ്സ്റ്റേഷൻ പ്രവർത്തനമാരംഭിച്ചിട്ടുണ്ട്. 5 MVA ശേഷിയുള്ള രണ്ട് 33/11 kV ട്രാൻസ്ഫോർമറുകൾ സ്ഥാപിച്ച് പ്രവർത്തിക്കുന്ന ടി സബ്സ്റ്റേഷൻ പൂർണ്ണമായും പ്രവർത്തനസജ്ജമാണ്.
(ബി)	നിലവിൽ പ്രസ്തുത സബ്സ്റ്റേഷന്റെ കപ്പാസിറ്റി എത്രയാണെന്നും, കപ്പാസിറ്റി വർദ്ധിപ്പിക്കാനുള്ള നടപടികൾ സ്വീകരിക്കുന്നുണ്ടോയെന്നും വിശദമാക്കാമോ;	(ബി)	നിലവിൽ 33 kV നിലവാരത്തിൽ 10 MVA ശേഷിയുള്ള വെനിയൂർ സബ്സ്റ്റേഷൻ 110 kV നിലവാരത്തിൽ 25 MVA ശേഷിയിലേക്ക് ഉയർത്തുന്നതിനുള്ള അനുമതികൾ നൽകി പ്രാരംഭ പ്രവൃത്തികൾ തുടങ്ങിയിട്ടുണ്ട്.
(സി)	പ്രസ്തുത പദ്ധതിയുടെ ആകെ തുക എത്രയാണെന്ന് ഭരണാനുമതിയുടെ പകർപ്പ് സഹിതം വിശദമാക്കാമോ.;	(സി)	പ്രസ്തുത പ്രവൃത്തിയുടെ ഭരണാനുമതി 19 കോടി രൂപയ്ക്കാണ് നൽകിയിട്ടുള്ളത്. ഇതിനുള്ള സാങ്കേതികാനുമതിയും നൽകിയിട്ടുണ്ട്. ഭരണാനുമതിയുടെ പകർപ്പ് <b>അനുബന്ധമായി</b> ചേർക്കുന്നു.
(ഡി)	വെനിയൂർ, പരപ്പനങ്ങാടി, എടരിക്കോട്, കൂരിയാട് എന്നീ സബ് സ്റ്റേഷനുകളെ തമ്മിൽ ബന്ധിപ്പിക്കുന്ന നടപടികൾ ഏതുവരെയായിരുന്നു ആയത് എന്നത്തേക്ക് പൂർത്തീകരിക്കാൻ കഴിയുമെന്നും വിശദമാക്കാമോ?	(ഡി)	എടരിക്കോട്, കൂരിയാട് സബ്സ്റ്റേഷനുകളെ ബന്ധിപ്പിച്ചുകൊണ്ട് 33 kV ലൈനുകൾ നിർമ്മാണം പൂർത്തീകരിച്ച് പ്രവർത്തനം ആരംഭിച്ചിട്ടുണ്ട്. വെനിയൂർ, പരപ്പനങ്ങാടി സബ്സ്റ്റേഷനുകളെ തമ്മിൽ ബന്ധിപ്പിക്കുന്ന 110 kV ലൈൻ നിർമ്മാണം പുരോഗമിച്ചുകൊണ്ടിരിക്കുന്നു. 2028 വർഷത്തോടെ പ്രവൃത്തി പൂർത്തിയാകുമെന്ന് പ്രതീക്ഷിക്കുന്നതായി KSEBL സർക്കാരിനെ അറിയിച്ചിട്ടുണ്ട്.

സെക്ഷൻ ഓഫീസർ


**KERALA STATE ELECTRICITY BOARD Ltd**

(Incorporated under the Companies Act, 1956)

Registered Office: Vidyuthi Bhavanam, Pattom, Thiruvananthapuram – 695 004

CIN: U40100KL2011SGC027424

Web: www.kseb.in

Phone :+91 471 2514576, 9446008884

Email :dlkseb@kseb.in

**ABSTRACT**

Construction of 110kV Substation at Venniyur including construction of 5 km 110kV Double Circuit LILO line from Edarikode-Parappanangadi line to Venniyur Substation - Administrative Sanction accorded - Orders issued

Office Order (DTSO) No. 841 /2024 [D(T&SO)/T4/Venniyur]  
Thiruvananthapuram

Dated:29-05-2024

- Read : 1. Letter No. D(T&SO)/PSE/SE-8/NP/2023-24/396 dated 25.01.2024 of the Executive Engineer, Power System Engineering  
2. Letter No. E.13995/FA/Fender-2/18/2024 dated 02.02.2024 of the Financial Advisor  
3. Minutes of the DPR Committee meeting held on 03.02.2024  
4. Letter No. CE/TRN/AE3/DB49/110kVS/s Venniyur/2023-24/2492 dated 27.02.2024 of the Chief Engineer [Transmission North]

**ORDER**

The Chief Engineer [Transmission North], as per letter read as 4<sup>th</sup> above, submitted an estimate amounting to Rs.19 Crore for the construction of a new 110kV Substation at Venniyur including construction of 5 km 110kV Double Circuit LILO line from Edarikode-Parappanangadi feeder to Venniyur substation.

The new substation is proposed to be constructed in the land available with KSEBL, received from M/s Steel Complex Ltd as part of settlement of pending electricity charge arrears. Load flow study has recommended the proposal vide letter read as 1<sup>st</sup> above. Financial Advisor recommended the project as financially viable, as per letter read as 2<sup>nd</sup> above.

The DPR Committee meeting held on 03.02.2024 approved the proposal subject to reviewing the proposal for optimizing the cost. Accordingly, the estimate is revised to Rs.19 Crore based on the latest Transmission Cost Data and labour data as per DSR 2018, and the Chief Engineer [Transmission North] requested sanction for the estimate.

The expenditure for the work shall be met from the budget provision for capital works under Transmission Circle Malappuram for the year 2024-25.

Having considered the matter in detail, Administrative Sanction is hereby accorded for the work "Construction of new 110kV Substation at Venniyur including construction of 5 km 110kV Double Circuit LILO line from Edarikode-Parappanangadi feeder to Venniyur

Substation" under Transmission Circle Malappuram, at an estimate amount of Rs.19 Crore [Rupees Nineteen Crore only].

Orders are issued accordingly.

By Order of the Director,  
Sd/-  
Ashajyothy M  
Deputy Secretary in charge  
of Secretary (Administration)

To:  
The Chief Engineer [Transmission North]

Copy to: Financial Advisor / Chief Internal Auditor  
Chief Engineer [IT, CR & CAPs]  
Deputy Chief Engineer, Transmission Circle, Malappuram  
TAs to Chairman & Managing Director / Director (Distribution, Safety & SCM) / Director (Transmission, SO & Planning )  
PA to Director (Finance & HRM)  
CA to Secretary (Administration)  
Stock File

Forwarded / By Order

*Dhananjay*  
Assistant Executive Engineer

Encl. On... DB2 / Venningan... / 2024-25 / 347 / 03.06.24  
Copy to EE TDM / EE TDT / AA AEE's / AA AEE's  
For information / necessary action and report.

*[Signature]*  
Deputy Chief Engineer  
Transmission Circle, Malappuram